



NOTE: ALL ROOF SHEATHING SHALL BE 3/4" APA RATED EXTERIOR SHEATHING ATTACHED W/8d WALLS @ 6" O.C. ALONG ALL EDGES AND 12" O.C. (MAX.) AT INTERMEDIATE SUPPORTS. THE ROOF SHEATHING SHALL BE LAD IN AN ALTERNATING PATTERN.

ROOF FRAMING PLAN

TRUSS BRG. EL.=122'-1 1/2" & TRUSS SPACING IS @ 2'-0" O.C. MAXIMUM (SEE ARCH. DRAWINGS FOR DIMENSIONS)

- TRUSS NOTES: 1. Lumber Specifications: Top and bottom chords to be No. 2 Southern Pine minimum. Web members to be No. 2 Southern Pine minimum. 2. Provide 2x4 cross bracing or bridging at all 1/3 points of the truss span for the bottom chord. All wood truss bracing shall conform to the Truss Plate Institute HB-(latest edition). 3. The erection and handling of the wood trusses must follow the Truss Plate Institute HB-(latest edition). 4. Truss gusset plates shall be steel, either nailed or glued-in, complying with the standards of the Truss Plate Institute HB-(latest edition). 5. The structural design of the wood trusses shall be based on the design loads shown. Should truss design or design loads vary from that shown, comply with local design codes. The Contractor shall submit truss shop drawings, including structural calculations, signed and sealed by a Structural Engineer, licensed to practice in Kentucky, for review. 6. Design loads for wood trusses are as follows: 10 psf bottom chord DL 35 psf top chord DL + LL 70 MPH per Kentucky Building Code

These Record Drawings have been prepared based on information provided by others. The Design Professional has not verified the accuracy and/or the completeness of this information and shall not be responsible for any errors or omissions which may be incorporated herein on a result.